

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-07-2012 - 31-07-2012 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 23

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.9600	0.9600	0.0000	0.96	0.96	1	0	0.96	0.96	100.00
	Fluoride (WU result)	1.5000	mg/L	0.9300	0.9300	0.0000	0.93	0.93	1	0	0.93	0.93	100.00
	Fluoride Ratio	0.8 - 1.2		0.9700	0.9700	0.0000	0.97	0.97	1	0	0.97	0.97	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	5.0000	mg/L	0.8425	0.8300	0.3812	0.41	1.3	4	0	1.3	0.41	100.00
	pH	6.5 - 8.5		7.5250	7.5000	0.2217	7.3	7.8	4	0	7.8	7.3	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3525	0.3700	0.1769	0.12	0.55	4	0	0.55	0.12	100.00