

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-06-2012 - 30-06-2012 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 18

| Analysis Type | Characteristic | Guideline Value | Units | Mean | Median | Standard Deviation | Min | Max | Sample Count | Exception Count | 95th Percentile | 5th Percentile | % meeting guideline values |
|------------------|----------------------|-----------------|------------|--------|--------|--------------------|------|------|--------------|-----------------|-----------------|----------------|----------------------------|
| Fluoride Barcode | | | | | | | | | | | | | |
| | Fluoride | 1.5000 | mg/L | 1.0800 | 1.0800 | 0.0000 | 1.08 | 1.08 | 1 | 0 | 1.08 | 1.08 | 100.00 |
| | Fluoride (WU result) | 1.5000 | mg/L | 1.1000 | 1.1000 | 0.0000 | 1.1 | 1.1 | 1 | 0 | 1.1 | 1.1 | 100.00 |
| | Fluoride Ratio | 0.8 - 1.2 | | 1.0200 | 1.0200 | 0.0000 | 1.02 | 1.02 | 1 | 0 | 1.02 | 1.02 | 100.00 |
| Microbiology | | | | | | | | | | | | | |
| | E. coli | 0.0000 | cfu/100 mL | 0.0000 | 0.0000 | 0.0000 | 0 | 0 | 3 | 0 | 0 | 0 | 100.00 |
| | Free Chlorine | 5.0000 | mg/L | 0.4300 | 0.2500 | 0.3559 | 0.2 | 0.84 | 3 | 0 | 0.84 | 0.2 | 100.00 |
| | pH | 6.5 - 8.5 | | 7.6000 | 7.8000 | 0.3464 | 7.2 | 7.8 | 3 | 0 | 7.8 | 7.2 | 100.00 |
| | Total Chlorine | 5.0000 | mg/L | 0.4000 | 0.4000 | 0.0000 | 0.4 | 0.4 | 1 | 0 | 0.4 | 0.4 | 100.00 |
| | Total Coliforms | 0.0000 | cfu/100 mL | 0.0000 | 0.0000 | 0.0000 | 0 | 0 | 3 | 0 | 0 | 0 | 100.00 |
| | Turbidity | 5.0000 | NTU | 0.3300 | 0.3300 | 0.0141 | 0.32 | 0.34 | 2 | 0 | 0.34 | 0.32 | 100.00 |