

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-09-2012 - 30-09-2012 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 23

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Plant													
	Fluoride	1.5000	mg/L	1.1500	1.1500	0.0000	1.15	1.15	1	0	1.15	1.15	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
	Fluoride Ratio	0.8 - 1.2		0.8900	0.8900	0.0000	0.89	0.89	1	0	0.89	0.89	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	5.0000	mg/L	0.4450	0.4550	0.2613	0.12	0.75	4	0	0.75	0.12	100.00
	pH	6.5 - 8.5		7.7000	7.7000	0.2944	7.4	8	4	0	8	7.4	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2875	0.2850	0.1480	0.13	0.45	4	0	0.45	0.13	100.00