

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-12-2012 - 31-12-2012 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 5

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride Ratio	0.8 - 1.2		0.5000	0.5000	0.0000	0.5	0.5	1	1	0.5	0.5	0.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6800	0.6150	0.3312	0.35	1.14	4	0	1.14	0.35	100.00
	pH	6.5 - 8.5		7.3333	7.3000	0.0577	7.3	7.4	3	0	7.4	7.3	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2475	0.2750	0.0826	0.13	0.31	4	0	0.31	0.13	100.00