

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-01-2013 - 31-01-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 6

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L	0.0600	0.0600	0.0000	0.06	0.06	1	0	0.06	0.06	100.00
	Fluoride Ratio	0.8 - 1.2		0.6000	0.6000	0.0000	0.6	0.6	1	1	0.6	0.6	0.00
Fluoride Plant													
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.9300	0.9100	0.0529	0.89	0.99	3	1	0.99	0.89	66.67
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	2	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6700	0.6700	0.8061	0.1	1.24	2	1	1.24	0.1	50.00
	pH	6.5 - 8.5		7.7000	7.7000	0.1414	7.6	7.8	2	0	7.8	7.6	100.00
	Total Chlorine	5.0000	mg/L	1.2400	1.2400	0.0000	1.24	1.24	1	0	1.24	1.24	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	2	0	0	0	100.00
	Turbidity	5.0000	NTU	0.0900	0.0900	0.0000	0.09	0.09	1	0	0.09	0.09	100.00