

Program:	Drinking Water Monitoring Program,Operational Monitoring Program,Project Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	All	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-03-2017 - 30-03-2017
Source:	All		
Sample Site:	All		

Sample Count: 6

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2000	1.2000	0.0000	1.2	1.2	1	0	1.2	1.2	100.00
	Fluoride (WU result)	1.5000	mg/L	1.2500	1.2500	0.0000	1.25	1.25	1	0	1.25	1.25	100.00
	Fluoride Ratio	0.8 - 1.2		1.0400	1.0400	0.0000	1.04	1.04	1	0	1.04	1.04	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.9880	0.9900	0.1545	0.78	1.16	5	0	1.16	0.78	100.00
	pH	6.5 - 8.5		7.4800	7.4000	0.1924	7.3	7.8	5	0	7.8	7.3	100.00
	Total Chlorine	5.0000	mg/L	1.1340	1.2000	0.1104	0.99	1.22	5	0	1.22	0.99	100.00

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3280	0.3000	0.1829	0.13	0.61	5	0	0.61	0.13	100.00