

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-04-2015 - 30-04-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 43

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1500	1.1500	0.0000	1.15	1.15	1	0	1.15	1.15	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1300	1.1300	0.0000	1.13	1.13	1	0	1.13	1.13	100.00
	Fluoride Ratio	0.8 - 1.2		0.9800	0.9800	0.0000	0.98	0.98	1	0	0.98	0.98	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0923	1.1000	0.0695	0.93	1.21	30	0	1.19	0.97	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0688	1.0950	0.0832	0.91	1.15	8	0	1.15	0.91	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6450	0.6650	0.2978	0.28	0.97	4	0	0.97	0.28	100.00
	pH	6.5 - 8.5		7.3500	7.3000	0.2646	7.1	7.7	4	0	7.7	7.1	100.00
	Total Chlorine	5.0000	mg/L	0.7550	0.8350	0.2817	0.35	1	4	0	1	0.35	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.0650	0.0600	0.0412	0.02	0.12	4	0	0.12	0.02	100.00