

Program:	Drinking Water Monitoring Program,Operational Monitoring Program,Project Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	All	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-04-2017 - 30-04-2017
Source:	All		
Sample Site:	All		

Sample Count: 4

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4775	0.2900	0.4029	0.25	1.08	4	0	1.08	0.25	100.00
	pH	6.5 - 8.5		7.5500	7.5000	0.1732	7.4	7.8	4	0	7.8	7.4	100.00
	Total Chlorine	5.0000	mg/L	0.7275	0.5550	0.4691	0.38	1.42	4	0	1.42	0.38	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3025	0.2150	0.2208	0.15	0.63	4	0	0.63	0.15	100.00