

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-08-2013 - 31-08-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 45

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1000	1.1000	0.0000	1.1	1.1	1	0	1.1	1.1	100.00
	Fluoride (WU result)	1.5000	mg/L	0.9500	0.9500	0.0000	0.95	0.95	1	0	0.95	0.95	100.00
	Fluoride Ratio	0.8 - 1.2		0.8600	0.8600	0.0000	0.86	0.86	1	0	0.86	0.86	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0319	1.0500	0.0913	0.82	1.25	31	2	1.16	0.88	93.55
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0138	1.0450	0.0819	0.87	1.08	8	1	1.08	0.87	87.50
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.0333	1.0800	0.2631	0.75	1.27	3	0	1.27	0.75	100.00
	pH	6.5 - 8.5		7.5500	7.7000	0.3697	7	7.8	4	0	7.8	7	100.00
	Total Chlorine	5.0000	mg/L	0.9700	0.9700	0.0000	0.97	0.97	1	0	0.97	0.97	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3025	0.2800	0.1255	0.18	0.47	4	0	0.47	0.18	100.00