

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-08-2014 - 31-08-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 5

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2100	1.2100	0.0000	1.21	1.21	1	0	1.21	1.21	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1000	1.1000	0.0000	1.1	1.1	1	0	1.1	1.1	100.00
	Fluoride Ratio	0.8 - 1.2		0.9100	0.9100	0.0000	0.91	0.91	1	0	0.91	0.91	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.5950	0.4300	0.4306	0.3	1.22	4	0	1.22	0.3	100.00
	pH	6.5 - 8.5		7.6250	7.6000	0.2217	7.4	7.9	4	0	7.9	7.4	100.00
	Total Chlorine	5.0000	mg/L	0.2400	0.2400	0.0000	0.24	0.24	1	0	0.24	0.24	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1967	0.1600	0.1290	0.09	0.34	3	0	0.34	0.09	100.00