

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-08-2015 - 31-08-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 43

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1365	1.1500	0.1105	0.9	1.36	31	0	1.35	0.98	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.1075	1.1000	0.0875	0.94	1.25	8	0	1.25	0.94	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.5950	0.5850	0.3260	0.22	0.99	4	0	0.99	0.22	100.00
	pH	6.5 - 8.5		7.3625	7.3750	0.1377	7.2	7.5	4	0	7.5	7.2	100.00
	Total Chlorine	5.0000	mg/L	0.8050	0.8250	0.3546	0.37	1.2	4	0	1.2	0.37	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.5150	0.3150	0.4606	0.23	1.2	4	0	1.2	0.23	100.00