

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-12-2013 - 31-12-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 47

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2000	1.2000	0.0000	1.2	1.2	1	0	1.2	1.2	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
	Fluoride Ratio	0.8 - 1.2		0.8500	0.8500	0.0000	0.85	0.85	1	0	0.85	0.85	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0235	1.0300	0.0613	0.89	1.13	31	1	1.13	0.9	96.77
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0120	1.0150	0.0634	0.92	1.13	10	0	1.13	0.92	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.5950	0.4650	0.4259	0.24	1.21	4	0	1.21	0.24	100.00
	pH	6.5 - 8.5		7.5300	7.4500	0.2110	7.3	7.8	5	0	7.8	7.3	100.00
	Total Chlorine	5.0000	mg/L	0.4500	0.4500	0.0000	0.45	0.45	1	0	0.45	0.45	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3500	0.3200	0.1181	0.19	0.49	5	0	0.49	0.19	100.00