

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-12-2014 - 31-12-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 5

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1000	1.1000	0.0000	1.1	1.1	1	0	1.1	1.1	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0700	1.0700	0.0000	1.07	1.07	1	0	1.07	1.07	100.00
	Fluoride Ratio	0.8 - 1.2		0.9700	0.9700	0.0000	0.97	0.97	1	0	0.97	0.97	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7275	0.7750	0.4360	0.18	1.18	4	1	1.18	0.18	75.00
	pH	6.5 - 8.5		7.3850	7.4000	0.1620	7.2	7.54	4	0	7.54	7.2	100.00
	Total Chlorine	5.0000	mg/L	0.4000	0.4000	0.0000	0.4	0.4	1	0	0.4	0.4	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1667	0.1500	0.1060	0.07	0.28	3	0	0.28	0.07	100.00