

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-12-2015 - 31-12-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 44

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.9850	0.9850	0.0919	0.92	1.05	2	0	1.05	0.92	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0500	1.0500	0.1273	0.96	1.14	2	0	1.14	0.96	100.00
	Fluoride Ratio	0.8 - 1.2		1.0650	1.0650	0.0354	1.04	1.09	2	0	1.09	1.04	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0565	1.0600	0.0824	0.86	1.19	31	2	1.19	0.89	93.55
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0550	1.0350	0.0721	0.96	1.18	8	0	1.18	0.96	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6333	0.8000	0.4917	0.08	1.02	3	1	1.02	0.08	66.67
	pH	6.5 - 8.5		7.5300	7.5000	0.0520	7.5	7.59	3	0	7.59	7.5	100.00
	Total Chlorine	5.0000	mg/L	0.6833	0.8400	0.4177	0.21	1	3	0	1	0.21	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2300	0.2200	0.1353	0.1	0.37	3	0	0.37	0.1	100.00