

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-02-2013 - 28-02-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 27

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L	0.0800	0.0800	0.0000	0.08	0.08	1	0	0.08	0.08	100.00
	Fluoride Ratio	0.8 - 1.2		0.8000	0.8000	0.0000	0.8	0.8	1	0	0.8	0.8	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1641	1.1500	0.0516	1.05	1.29	17	0	1.29	1.05	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0025	1.0150	0.0512	0.93	1.05	4	0	1.05	0.93	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7220	0.6200	0.4447	0.32	1.43	5	0	1.43	0.32	100.00
	pH	6.5 - 8.5		7.7800	7.7000	0.2588	7.5	8.1	5	0	8.1	7.5	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3900	0.2100	0.3473	0.12	0.9	5	0	0.9	0.12	100.00