

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-02-2014 - 28-02-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 41

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1800	1.1800	0.0000	1.18	1.18	1	0	1.18	1.18	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0800	1.0800	0.0000	1.08	1.08	1	0	1.08	1.08	100.00
	Fluoride Ratio	0.8 - 1.2		0.9200	0.9200	0.0000	0.92	0.92	1	0	0.92	0.92	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0339	1.0450	0.0533	0.9	1.1	28	0	1.1	0.95	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.9925	0.9750	0.0377	0.95	1.04	8	0	1.04	0.95	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4075	0.2750	0.3931	0.1	0.98	4	1	0.98	0.1	75.00
	pH	6.5 - 8.5		7.4000	7.3500	0.2160	7.2	7.7	4	0	7.7	7.2	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.9000	0.6400	0.8709	0.16	2.16	4	0	2.16	0.16	100.00