

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-02-2015 - 28-02-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 41

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2500	1.2500	0.0000	1.25	1.25	1	0	1.25	1.25	100.00
	Fluoride (WU result)	1.5000	mg/L	0.9800	0.9800	0.0000	0.98	0.98	1	0	0.98	0.98	100.00
	Fluoride Ratio	0.8 - 1.2		0.7800	0.7800	0.0000	0.78	0.78	1	1	0.78	0.78	0.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0386	1.0300	0.0845	0.8	1.16	28	1	1.15	0.9	96.43
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0313	1.0650	0.0755	0.91	1.13	8	0	1.13	0.91	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.3650	0.1400	0.4850	0.09	1.09	4	3	1.09	0.09	25.00
	pH	6.5 - 8.5		7.4250	7.5000	0.2217	7.1	7.6	4	0	7.6	7.1	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.0925	0.0950	0.0171	0.07	0.11	4	0	0.11	0.07	100.00