

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-02-2016 - 29-02-2016 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 42

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1400	1.1400	0.0000	1.14	1.14	1	0	1.14	1.14	100.00
	Fluoride (WU result)	1.5000	mg/L	0.9000	0.9000	0.0000	0.9	0.9	1	0	0.9	0.9	100.00
	Fluoride Ratio	0.8 - 1.2		0.7900	0.7900	0.0000	0.79	0.79	1	1	0.79	0.79	0.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0459	1.0400	0.0854	0.85	1.26	29	1	1.21	0.94	96.55
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.9825	0.9700	0.0997	0.86	1.15	8	2	1.15	0.86	75.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7875	0.6750	0.2630	0.62	1.18	4	0	1.18	0.62	100.00
	pH	6.5 - 8.5		7.4750	7.4500	0.1708	7.3	7.7	4	0	7.7	7.3	100.00
	Total Chlorine	5.0000	mg/L	0.9875	0.8850	0.2871	0.77	1.41	4	0	1.41	0.77	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1650	0.1400	0.0790	0.1	0.28	4	0	0.28	0.1	100.00