

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-01-2014 - 31-01-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 44

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.0800	1.0800	0.0000	1.08	1.08	1	0	1.08	1.08	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
	Fluoride Ratio	0.8 - 1.2		0.9400	0.9400	0.0000	0.94	0.94	1	0	0.94	0.94	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.9913	0.9900	0.0580	0.87	1.08	31	2	1.08	0.89	93.55
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.9486	0.9400	0.0434	0.9	1.01	7	0	1.01	0.9	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.3580	0.4100	0.2422	0.1	0.7	5	2	0.7	0.1	60.00
	pH	6.5 - 8.5		7.5260	7.6000	0.1545	7.33	7.7	5	0	7.7	7.33	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3260	0.3200	0.1130	0.18	0.48	5	0	0.48	0.18	100.00