

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-01-2016 - 31-01-2016 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 44

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.9800	0.9800	0.0000	0.98	0.98	1	0	0.98	0.98	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0500	1.0500	0.0000	1.05	1.05	1	0	1.05	1.05	100.00
	Fluoride Ratio	0.8 - 1.2		1.0700	1.0700	0.0000	1.07	1.07	1	0	1.07	1.07	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0294	1.0200	0.0613	0.95	1.16	31	0	1.15	0.95	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.9788	0.9300	0.0976	0.88	1.15	8	1	1.15	0.88	87.50
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4200	0.4500	0.2443	0.1	0.68	4	1	0.68	0.1	75.00
	pH	6.5 - 8.5		7.6250	7.6000	0.1500	7.5	7.8	4	0	7.8	7.5	100.00
	Total Chlorine	5.0000	mg/L	0.5875	0.6250	0.2571	0.24	0.86	4	0	0.86	0.24	100.00
	Total Coliforms	0.0000	mpn/100 mL	4.5000	0.0000	9.0000	0	18	4	1	18	0	75.00
	Turbidity	5.0000	NTU	0.2325	0.2050	0.1343	0.11	0.41	4	0	0.41	0.11	100.00