

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-07-2014 - 31-07-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: Many

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 47

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	0.9000	0.9000	0.0000	0.9	0.9	1	0	0.9	0.9	100.00
	Fluoride (WU result)	1.5000	mg/L	0.9200	0.9200	0.0000	0.92	0.92	1	0	0.92	0.92	100.00
	Fluoride Ratio	0.8 - 1.2		1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0532	1.0400	0.1036	0.85	1.25	31	1	1.21	0.92	96.77
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0280	1.0050	0.1134	0.9	1.25	10	0	1.25	0.9	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4160	0.4000	0.3624	0.07	0.97	5	2	0.97	0.07	60.00
	pH	6.5 - 8.5		7.4800	7.5000	0.1643	7.2	7.6	5	0	7.6	7.2	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2600	0.2100	0.1351	0.18	0.5	5	0	0.5	0.18	100.00