

Program:	Drinking Water Program,Operational Monitoring Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	All	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-07-2016 - 31-07-2016
Source:	All		
Sample Site:	All		

Sample Count: 44

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1300	1.1300	0.0000	1.13	1.13	1	0	1.13	1.13	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1300	1.1300	0.0000	1.13	1.13	1	0	1.13	1.13	100.00
	Fluoride Ratio	0.8 - 1.2		1.0000	1.0000	0.0000	1	1	1	0	1	1	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.5350	0.5650	0.2933	0.2	0.81	4	0	0.81	0.2	100.00
	pH	6.5 - 8.5		7.5250	7.5000	0.1500	7.4	7.7	4	0	7.7	7.4	100.00
	Total Chlorine	5.0000	mg/L	0.5825	0.6400	0.2779	0.2	0.85	4	0	0.85	0.2	100.00

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1200	0.1200	0.0163	0.1	0.14	4	0	0.14	0.1	100.00
Operational Monitoring													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1348	1.1400	0.1138	0.91	1.42	31	0	1.38	0.93	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0888	1.1000	0.0629	1	1.18	8	0	1.18	1	100.00