

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-06-2015 - 30-06-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 45

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2200	1.2200	0.0000	1.22	1.22	1	0	1.22	1.22	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1600	1.1600	0.0000	1.16	1.16	1	0	1.16	1.16	100.00
	Fluoride Ratio	0.8 - 1.2		0.9500	0.9500	0.0000	0.95	0.95	1	0	0.95	0.95	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1580	1.1550	0.0728	0.98	1.3	30	0	1.3	1.07	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.1080	1.1050	0.0557	1.01	1.19	10	0	1.19	1.01	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.0400	1.0700	0.2920	0.66	1.36	4	0	1.36	0.66	100.00
	pH	6.5 - 8.5		7.5750	7.5000	0.2217	7.4	7.9	4	0	7.9	7.4	100.00
	Total Chlorine	5.0000	mg/L	1.1475	1.1350	0.2481	0.86	1.46	4	0	1.46	0.86	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2550	0.2100	0.1714	0.1	0.5	4	0	0.5	0.1	100.00