

Program:	Drinking Water Program,Operational Monitoring Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	All	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-06-2016 - 30-06-2016
Source:	All		
Sample Site:	All		

Sample Count: 42

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2200	1.2200	0.0000	1.22	1.22	1	0	1.22	1.22	100.00
	Fluoride (WU result)	1.5000	mg/L	1.2400	1.2400	0.0000	1.24	1.24	1	0	1.24	1.24	100.00
	Fluoride Ratio	0.8 - 1.2		1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6525	0.6200	0.5324	0.18	1.19	4	1	1.19	0.18	75.00
	pH	6.5 - 8.5		7.7000	7.6500	0.5715	7.1	8.4	4	0	8.4	7.1	100.00
	Total Chlorine	5.0000	mg/L	0.7875	0.7950	0.5758	0.25	1.31	4	0	1.31	0.25	100.00

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2100	0.2100	0.0993	0.09	0.33	4	0	0.33	0.09	100.00
Operational Monitoring													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1697	1.1800	0.0895	0.92	1.3	29	0	1.3	1.04	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.1600	1.1550	0.0293	1.11	1.2	8	0	1.2	1.11	100.00