

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-03-2013 - 31-03-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 44

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2100	1.2100	0.0000	1.21	1.21	1	0	1.21	1.21	100.00
	Fluoride (WU result)	1.5000	mg/L	1.2200	1.2200	0.0000	1.22	1.22	1	0	1.22	1.22	100.00
	Fluoride Ratio	0.8 - 1.2		1.0100	1.0100	0.0000	1.01	1.01	1	0	1.01	1.01	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1232	1.1200	0.0539	0.98	1.22	31	0	1.21	1.04	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0688	1.0750	0.0449	1	1.13	8	0	1.13	1	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.8267	0.6500	0.3412	0.61	1.22	3	0	1.22	0.61	100.00
	pH	6.5 - 8.5		7.6250	7.8000	0.4193	7	7.9	4	0	7.9	7	100.00
	Total Chlorine	5.0000	mg/L	1.4700	1.4700	0.0000	1.47	1.47	1	0	1.47	1.47	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.2500	0.0000	0.5000	0	1	4	1	1	0	75.00
	Turbidity	5.0000	NTU	0.3325	0.2150	0.3166	0.1	0.8	4	0	0.8	0.1	100.00