

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-03-2014 - 31-03-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 45

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1700	1.1700	0.0000	1.17	1.17	1	0	1.17	1.17	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1300	1.1300	0.0000	1.13	1.13	1	0	1.13	1.13	100.00
	Fluoride Ratio	0.8 - 1.2		0.9700	0.9700	0.0000	0.97	0.97	1	0	0.97	0.97	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0194	1.0300	0.0848	0.85	1.16	31	3	1.15	0.85	90.32
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0500	1.0600	0.0462	0.98	1.11	10	0	1.11	0.98	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4950	0.4950	0.1768	0.37	0.62	2	0	0.62	0.37	100.00
	pH	6.5 - 8.5		7.4333	7.5000	0.1155	7.3	7.5	3	0	7.5	7.3	100.00
	Total Chlorine	5.0000	mg/L	0.7400	0.7400	0.0000	0.74	0.74	1	0	0.74	0.74	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3067	0.3900	0.1531	0.13	0.4	3	0	0.4	0.13	100.00