

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-05-2014 - 31-05-2014 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 35

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1900	1.1900	0.0000	1.19	1.19	1	0	1.19	1.19	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1400	1.1400	0.0000	1.14	1.14	1	0	1.14	1.14	100.00
	Fluoride Ratio	0.8 - 1.2		0.9600	0.9600	0.0000	0.96	0.96	1	0	0.96	0.96	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0713	1.0800	0.0678	0.95	1.21	31	0	1.16	0.95	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.3200	0.3600	0.1539	0.15	0.45	3	1	0.45	0.15	66.67
	pH	6.5 - 8.5		7.6333	7.6000	0.1528	7.5	7.8	3	0	7.8	7.5	100.00
	Total Chlorine	5.0000	mg/L	0.3500	0.3500	0.0000	0.35	0.35	1	0	0.35	0.35	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3300	0.3300	0.0990	0.26	0.4	2	0	0.4	0.26	100.00