

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-05-2016 - 31-05-2016 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 47

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.0000	1.0000	0.0000	1	1	1	0	1	1	100.00
	Fluoride (WU result)	1.5000	mg/L	0.9300	0.9300	0.0000	0.93	0.93	1	0	0.93	0.93	100.00
	Fluoride Ratio	0.8 - 1.2		0.9300	0.9300	0.0000	0.93	0.93	1	0	0.93	0.93	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1235	1.1800	0.1109	0.89	1.27	31	1	1.25	0.9	96.77
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.1110	1.1200	0.0872	0.95	1.24	10	0	1.24	0.95	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7680	0.7100	0.4205	0.32	1.23	5	0	1.23	0.32	100.00
	pH	6.5 - 8.5		7.8400	7.8000	0.1140	7.7	8	5	0	8	7.7	100.00
	Total Chlorine	5.0000	mg/L	0.9180	1.1200	0.4068	0.41	1.27	5	0	1.27	0.41	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1540	0.1100	0.0789	0.09	0.24	5	0	0.24	0.09	100.00