

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-11-2013 - 30-11-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 43

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1800	1.1800	0.0000	1.18	1.18	1	0	1.18	1.18	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0600	1.0600	0.0000	1.06	1.06	1	0	1.06	1.06	100.00
	Fluoride Ratio	0.8 - 1.2		0.9000	0.9000	0.0000	0.9	0.9	1	0	0.9	0.9	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0623	1.0950	0.1011	0.75	1.21	30	2	1.18	0.89	93.33
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0200	1.0050	0.0481	0.96	1.11	8	0	1.11	0.96	100.00
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4950	0.4750	0.1848	0.3	0.73	4	0	0.73	0.3	100.00
	pH	6.5 - 8.5		7.4625	7.4500	0.1109	7.35	7.6	4	0	7.6	7.35	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2675	0.2050	0.2360	0.08	0.58	4	0	0.58	0.08	100.00