

Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-11-2015 - 30-11-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 43

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1400	1.1400	0.0000	1.14	1.14	1	0	1.14	1.14	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1900	1.1900	0.0000	1.19	1.19	1	0	1.19	1.19	100.00
	Fluoride Ratio	0.8 - 1.2		1.0400	1.0400	0.0000	1.04	1.04	1	0	1.04	1.04	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0700	1.0950	0.0978	0.84	1.2	30	1	1.19	0.91	96.67
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.1013	1.1250	0.0779	0.98	1.19	8	0	1.19	0.98	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7200	0.7450	0.5326	0.1	1.29	4	1	1.29	0.1	75.00
	pH	6.5 - 8.5		7.4000	7.4500	0.1414	7.2	7.5	4	0	7.5	7.2	100.00
	Total Chlorine	5.0000	mg/L	0.9400	0.9100	0.5415	0.38	1.56	4	0	1.56	0.38	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2975	0.2850	0.1011	0.19	0.43	4	0	0.43	0.19	100.00