

## Result Summary Report

Program:	Drinking Water Program	Barcode:	All
Collected Date Range:	01-10-2015 - 31-10-2015	Entered Date Range:	-
AHS:	All		
PHU:	All		
Water Utility:	All		
Supply System:	All		
Analysis Type:	All		
Characteristics:	All		
Treatment Plant:	Many		
Treatment Type:	All		
Source:	All		
Town:	All		
Sample Site:	All		
Sample Count:	44		

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1400	1.1400	0.0000	1.14	1.14	1	0	1.14	1.14	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1600	1.1600	0.0000	1.16	1.16	1	0	1.16	1.16	100.00
	Fluoride Ratio	0.8 - 1.2		1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1652	1.1600	0.0927	0.99	1.32	31	0	1.32	0.99	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.1563	1.1700	0.0403	1.09	1.21	8	0	1.21	1.09	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6300	0.5200	0.5552	0.15	1.33	4	1	1.33	0.15	75.00
	pH	6.5 - 8.5		7.5500	7.6000	0.1915	7.3	7.7	4	0	7.7	7.3	100.00
	Total Chlorine	5.0000	mg/L	0.6750	0.4650	0.5358	0.3	1.47	4	0	1.47	0.3	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2075	0.2100	0.0892	0.1	0.31	4	0	0.31	0.1	100.00