

Program:	Drinking Water Monitoring Program,Operational Monitoring Program,Project Program	Report Type:	Results Summary Report
AHS:	All	Entered Date Range:	-
PHU:	All	Barcode:	All
Water Utility:	All	Analysis Type:	All
Supply System:	All	Characteristics:	All
Town:	All	Treatment Type:	All
Treatment Plant:	All	Collected Date Range:	01-10-2016 - 31-10-2016
Source:	All		
Sample Site:	All		

Sample Count: 33

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.2400	1.2400	0.0000	1.24	1.24	1	0	1.24	1.24	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1100	1.1100	0.0000	1.11	1.11	1	0	1.11	1.11	100.00
	Fluoride Ratio	0.8 - 1.2		0.9000	0.9000	0.0000	0.9	0.9	1	0	0.9	0.9	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.2550	0.2150	0.1593	0.11	0.48	4	2	0.48	0.11	50.00
	pH	6.5 - 8.5		7.4500	7.4500	0.0577	7.4	7.5	4	0	7.5	7.4	100.00
	Total Chlorine	5.0000	mg/L	0.4450	0.4450	0.1760	0.23	0.66	4	0	0.66	0.23	100.00

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1600	0.1500	0.0346	0.13	0.21	4	0	0.21	0.13	100.00
Operational Monitoring													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.1527	1.1800	0.1070	0.92	1.3	22	0	1.3	0.92	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0533	1.0550	0.0677	0.95	1.15	6	0	1.15	0.95	100.00