

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-09-2013 - 30-09-2013 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 44

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.0700	1.0700	0.0000	1.07	1.07	1	0	1.07	1.07	100.00
	Fluoride (WU result)	1.5000	mg/L	1.1000	1.1000	0.0000	1.1	1.1	1	0	1.1	1.1	100.00
	Fluoride Ratio	0.8 - 1.2		1.0300	1.0300	0.0000	1.03	1.03	1	0	1.03	1.03	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0263	1.0350	0.0768	0.8	1.13	30	2	1.13	0.88	93.33
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0325	1.0700	0.0884	0.85	1.11	8	1	1.11	0.85	87.50
Microbiology													
	E. coli	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6250	0.5400	0.4159	0.22	1.2	4	0	1.2	0.22	100.00
	pH	6.5 - 8.5		7.7000	7.7500	0.1414	7.5	7.8	4	0	7.8	7.5	100.00
	Total Coliforms	0.0000	cfu/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.6750	0.2500	0.8837	0.2	2	4	0	2	0.2	100.00