

Result Summary Report

Program:	Drinking Water Program	Barcode:	All
Collected Date Range:	01-09-2014 - 30-09-2014	Entered Date Range:	-
AHS:	All		
PHU:	All		
Water Utility:	All		
Supply System:	All		
Analysis Type:	All		
Characteristics:	All		
Treatment Plant:	Many		
Treatment Type:	All		
Source:	All		
Town:	All		
Sample Site:	All		
Sample Count:	46		

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.1600	1.1600	0.0000	1.16	1.16	1	0	1.16	1.16	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0200	1.0200	0.0000	1.02	1.02	1	0	1.02	1.02	100.00
	Fluoride Ratio	0.8 - 1.2		0.8800	0.8800	0.0000	0.88	0.88	1	0	0.88	0.88	100.00
Fluoride Plant													
	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.0337	1.0250	0.0897	0.9	1.2	30	0	1.19	0.9	100.00
	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.0120	1.0250	0.0459	0.92	1.07	10	0	1.07	0.92	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.5160	0.6100	0.2492	0.11	0.76	5	1	0.76	0.11	80.00
	pH	6.5 - 8.5		7.8400	7.9000	0.1517	7.6	8	5	0	8	7.6	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2400	0.2000	0.1075	0.11	0.39	5	0	0.39	0.11	100.00