

## Result Summary Report

Program: Drinking Water Program Barcode: All

Collected Date Range: 01-09-2015 - 30-09-2015 Entered Date Range: -

AHS: All

PHU: All

Water Utility: All

Supply System: All

Analysis Type: All

Characteristics: All

Treatment Plant: All

Treatment Type: All

Source: All

Town: All

Sample Site: All

Sample Count: 6

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode													
	Fluoride	1.5000	mg/L	1.0300	1.0300	0.0000	1.03	1.03	1	0	1.03	1.03	100.00
	Fluoride (WU result)	1.5000	mg/L	1.0600	1.0600	0.0000	1.06	1.06	1	0	1.06	1.06	100.00
	Fluoride Ratio	0.8 - 1.2		1.0300	1.0300	0.0000	1.03	1.03	1	0	1.03	1.03	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.3720	0.3400	0.2036	0.18	0.67	5	1	0.67	0.18	80.00
	pH	6.5 - 8.5		7.3400	7.3000	0.0548	7.3	7.4	5	0	7.4	7.3	100.00
	Total Chlorine	5.0000	mg/L	0.4480	0.4400	0.1420	0.28	0.65	5	0	0.65	0.28	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2980	0.3200	0.1497	0.09	0.48	5	0	0.48	0.09	100.00